



## WORK ORDER #: WO79268



## EMERGENCY SERVICE

**Address:** 415 Ambassador Dr., Mississauga ON L5T 2J3

**Toll-free:** 1 (866) 601-1758 | **F:** (905) 625-0187 | **E:** [service@northerndocksystems.com](mailto:service@northerndocksystems.com)

### Customer Information

Sinclair Supply LTD.  
10914 - 120 St  
Edmonton, T5H 3P7  
AB, Canada

### Service Location


Sinclair Supply LTD.  
10914 - 120 St  
Edmonton, T5H 3P7  
AB, Canada

### Service Details

<b>Created</b>	6/23/2021 10:16 AM	<b>Last Updated</b>	6/24/2021 5:01 AM
<b>Type</b>	Local Service	<b>Priority</b>	
<b>Status</b>	Open - Completed	<b>Last Visit Date</b>	6/23/2021
<b>Next Step</b>	No Action Required – internal	<b>Field Specialist</b>	Rafael
<b>Primary Incident Type</b>	Dock Service	<b>Signed By</b>	
<b>Customer Asset</b>	Position 5 - Dock	<b>P.O #</b>	Email
<b>Scope of Work</b>	Leaking hose on dock 5. Assess and repair.		

### Execution Notes

	Details	Content
<b>Created On:</b> 6/23/2021 2:16 PM  <b>Created By:</b> Rafael	Arrived on site and found that hose had been cut though by dock lip. Removed broken hose, ground off sharp edges on dock lip and made opening big enough for new hoses.	

<p><b>Created On:</b> 6/23/2021 2:52 PM</p> <p><b>Created By:</b> Rafael</p>	<p>Installed new hoses and tested dock for proper operation. Hoses aren't rubbing anymore and dock is functioning properly.</p>	
<p><b>Created On:</b> 6/23/2021 4:21 PM</p> <p><b>Created By:</b> Rafael</p>	<p>Completed job.</p>	